

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:14 pm

PWS ID: UTAH16001 **Name:** JUNCTION TOWN
Legal Contact: JUNCTION **Rating:** Approved
 COREY Y FULLMER **Rating Date:** 04/16/1986
Address: PO BOX 96 **Activity Status:** Active
 JUNCTION, UT 84740
Phone Number: 435-577-2569
City Served (Area):
County: PIUTE COUNTY

System Type: Community **Last Inv Update:** 05/25/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 08/04/2008 **Total Dsgn Cap:**
Population: 190 **Surveyor:** JOHN H OAKESON **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers Office Emergency	Email Address
AC	FULLMER, COREY Y	MANAGER	435-577-2569	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	115
Commercial	Metered	0	4
Agricultural	Metered	0	1
			120 Total Svc Connections

Storage

Total Storage: 375,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	EAST TANK	Ground	250,000 GAL	Concrete		A	NO
ST002	WEST TANK	Ground	125,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	CITY CREEK SPRING CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	CITY CREEK SPRING #1	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	TOWN WELL	Active	WL	6	1200 GPM	227 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	UTAH16006 CITY CREEK CA	Inactive	CC				Yes	GW	Permanent		

*Reports measured flow for wells, approved design capacity for all other sources.